

8

## Annexure- C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 128

Dated: 20/05/2026

It is certified that an inspection team headed by Dr. Pooja Hume M.B.B.S. (Name of Officers with designation) from P.H.C. Soni PHED inspected the **Mount Camet Public School, Thana Road, Goregaon, Taluka Goregaon, District Gondia, State-Maharashtra-441801** (Name & Address of the school) on 20/05/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **339 dated 08/05/2026** of **District water testing laboratory** (PHED Lab) certified that the **Mount Camet Public School, Thana Road, Goregaon** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 19.05.2027

*P. Hume*

Medical Officer  
Primary Health Centre:  
Soni Dist Gondia

Signature with Seal: .....

Name : Dr. Pooja Hume

Designation : M.B.B.S.

Name & Address of the Office /  
Department: PHC. Soni

Health department



To

**Mount Camet Public School,**  
**Thana Road, Goregaon, Taluka Goregaon,**  
**District Gondia, State-Maharashtra-441801**  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

*A. J. J.*  
**Manager**  
**Mount Camet Public School**  
**GOREGAON**

*Y. J.*  
**Principal**  
**Mount Camet Public School**  
**GOREGAON**

8



**DISTRICT WATER QUALITY TESTING LABORATORY**  
**GROUNDWATER SURVEYS & DEVELOPMENT AGENCY, GONDIA**  
**DISTRICT GONDIA REGION NAGPUR**

DWTL/PRO/02

Sample Test Report

**FOR NON ACCREDITATED PARAMETERS**

<b>Issued To :</b>	<b>Principal, Mount Camet Public School, Goregaon, Taluka-Goregaon, District-Gondia.</b>				
<b>01</b>	Sample Inward No:	<b>DWTL/GSDA/GON/04/04/2026</b>			
<b>02</b>	Inward Date :	20.04.2026	<b>14</b>	Analysis Start Date:	21.04.2026
<b>03</b>	Reference Letter No. :	146/2026	<b>15</b>	<b>Environmental Condition</b>	
<b>04</b>	Reference Letter Date :	20.04.2026	<b>A</b>	Temp. (°C) :	25 °C
<b>05</b>	Sample :	Water	<b>B</b>	Humidity (%) :	56 %
<b>06</b>	Sample Category :	Water	<b>16</b>	Analysis End Date :	30.04.2026
<b>07</b>	Quantity Received :	01 Litre	<b>10</b>	Sample Source:	See Below
<b>08</b>	Sampling Date :	20.04.2026	<b>11</b>	Sample Collected by :	Client
<b>09</b>	Sampling Time :	01.45 pm	<b>12</b>	Sampling Location :	See Below
			<b>13</b>	Sample Details :	See Below
	<b>Analysed For</b>	<b>Yes /No</b>		<b>Analysed For</b>	<b>Yes /No</b>
<b>01</b>	Calcium	<b>No</b>	<b>08</b>	Turbidity	<b>Yes</b>
<b>02</b>	Chloride	<b>Yes</b>	<b>09</b>	Bicarbonate	<b>No</b>
<b>03</b>	Colour	<b>Yes</b>	<b>10</b>	Carbonate	<b>No</b>
<b>04</b>	Magnesium	<b>No</b>	<b>11</b>	Sulphate	<b>Yes</b>
<b>04</b>	Odour	<b>Yes</b>	<b>12</b>	Total Coliforms	<b>Yes</b>
<b>04</b>	Taste	<b>Yes</b>	<b>13</b>	E. Coliforms	<b>Yes</b>
<b>07</b>	Total Alkalinity	<b>Yes</b>			
<b>Remarks :</b>					
<ul style="list-style-type: none"> <li>The results relate only to the samples tested.</li> <li>The report shall not be reproduced except in full, without the written approval of the laboratory.</li> <li>Parameters in this report are not covered in NABL scope.</li> <li>The Sample is collected by the client himself. As such the laboratory has no involvement in sample collection.</li> </ul>					

**TEST RESULTS FOR NON ACCREDITATED PARAMETERS**

Sr. No.	Test Parameter	Measurement Unit	Requirement as per IS10500 : 2012 (Drinking Water Specifications)		Test Result
			Desirable Limit	Permissible Limit	
<b>1</b>	Calcium	mg/L	75	200	-
<b>2</b>	Chloride	mg/L	250	1000	15
<b>3</b>	Colour	Hazen Unit	5	15	0.52
<b>4</b>	Magnesium	mg/L	30	100	-
<b>5</b>	Odour	-	-	-	Agreeable
<b>6</b>	Taste	-	-	-	Agreeable
<b>7</b>	Total Alkalinity	mg/L	200	600	10
<b>8</b>	Turbidity	NTU	1	5	0.27
<b>9</b>	Bicarbonate	mg/L	-	-	-
<b>10</b>	Carbonate	mg/L	-	-	-
<b>11</b>	Sulphate	mg/L	200	400	1.70
<b>12</b>	Total Coliforms	MPN	0	0	0
<b>13</b>	E. Coliforms	MPN	0	0	0

Reviewed By

(Bacteriologist)

Authorised By

(TM/Chemist)



**DISTRICT WATER QUALITY TESTING LABORATORY**  
**GROUNDWATER SURVEYS & DEVELOPMENT AGENCY, GONDIA**  
**DISTRICT GONDIA REGION NAGPUR**

DWTL/PRO/02                      Sample Test Report

**Sample Details**

Sr. No.	SAMPLE CODE	LAB REF. NUMBER	VILLAGE	TALUKA	DISTRICT	SOURCE	SOURCE LOCATION
1	S1	DWTL/GSDA/ GON/04/04/ 2026	Goregaon	Goregaon	Gondia	Borewell	Mount Camet Public School, Goregaon, Taluka-Goregaon, District-Gondia.

Sr. No.	Test Parameter	Test Method
01	Calcium	APHA 24 <sup>th</sup> EDN, METHOD 3500Ca-B
02	Chloride	APHA 24 <sup>th</sup> EDN, METHOD 4500Cl-B
03	Colour	APHA 24 <sup>th</sup> EDN, METHOD 2120C
04	Magnesium	APHA 24 <sup>th</sup> EDN, METHOD 4500
05	Odour	IS 3025 (PART 5)
06	Taste	IS 3025 (PART 7)
07	Total Alkalinity	APHA 24 <sup>th</sup> EDN, METHOD 2320B
08	Turbidity	APHA 24 <sup>th</sup> EDN, METHOD 2130B
09	Bicarbonate	APHA 24 <sup>th</sup> EDN, METHOD
10	Carbonate	APHA 24 <sup>th</sup> EDN, METHOD
11	Sulphate	APHA 24 <sup>th</sup> EDN, METHOD 4500 SO <sub>4</sub> -B
12	Total Coliforms	Multiple Tube Dilution technique
13	E. Coliforms	Multiple Tube Dilution technique

\*\*\*\*\*End of Report\*\*\*\*\*

  
**Manager**  
Mount Camet Public School  
GOREGAON

  
**Principal**  
Mount Camet Public School  
GOREGAON

**DISTRICT WATER QUALITY TESTING LABORATORY**  
GROUNDWATER SURVEYS & DEVELOPMENT AGENCY, GONDIA  
DISTRICT GONDIA REGION NAGPUR



DWTL/PRO/02

Sample Test Report

Outward No.	339		Date:	08-05-2026	
Issued To :	Principal, Mount Camet Public School, Goregaon, Taluka-Goregaon, District-Gondia.				
01	Sample Inward No:	DWTL/GSDA/GON/04/04/2026			
02	Inward Date :	20.04.2026	14	Analysis Start Date:	21.04.2026
03	Reference Letter No. :	146/2026	15	<b>Environmental Condition</b>	
04	Reference Letter Date :	20.04.2026	A	Temp. (°C) :	25 °C
05	Sample :	Water	B	Humidity (%) :	56 %
06	Sample Category :	Water	16	Analysis End Date :	30.04.2026
07	Quantity Received :	01 Litre	10	Sample Source:	See Below
08	Sampling Date :	20.04.2026	11	Sample Collected by :	Client
09	Sampling Time :	01.45 pm	12	Sampling Location :	See Below
			13	Sample Details :	See Below
	<b>Analysed For</b>	<b>Yes /No</b>	<b>Remarks :</b>		
01	pH	Yes	<ul style="list-style-type: none"> <li>The results relate only to the samples tested.</li> <li>The report shall not be reproduced except in full, without the written approval of the laboratory.</li> <li>The Sample is collected by the client himself. As such the laboratory has no involvement in sample collection.</li> </ul>		
02	Electrical Conductivity	Yes			
03	TDS	Yes			
04	Total Hardness	Yes			
05	Nitrate	Yes			
06	Fluoride	Yes			
07	Iron	Yes			

**TEST RESULTS FOR ACCREDITATED PARAMETERS**

Sr. No.	Test Parameter	Measurement Unit	Requirement as per IS10500 : 2012 (Drinking Water Specifications)		Test Result
			Desirable Limit	Permissible Limit	
1	pH	-	6.5 To 8.5	No Relaxation	7.30
2	Electrical Conductivity	uS/cm	-	-	107
3	TDS	mg/L	500	2000	72
4	Total Hardness	mg/L	200	600	40
5	Nitrate	mg/L	45	No Relaxation	0.77
6	Fluoride	mg/L	1.0	1.5	0.36
7	Iron	mg/L	1.0	No Relaxation	0.43

**Sample Details**

Sr No.	SAMPLE CODE	LAB REF. NUMBER	VILLAGE	TALUKA	DISTRICT
1	S1	DWTL/GSDA/GON/04/04/2026	Goregaon	Goregaon	Gondia

**TEST METHOD EMPLOYED**

Sr. No.	Test Parameter	Test Method
01	pH	APHA 24 <sup>th</sup> EDN, METHOD 4500
02	Electrical Conductivity	APHA 24 <sup>th</sup> EDN, METHOD 2510B
03	TDS	APHA 24 <sup>th</sup> EDN, METHOD 2540C
04	Total Hardness	APHA 24 <sup>th</sup> EDN, METHOD 2340C
05	Nitrate	APHA 24 <sup>th</sup> EDN, METHOD 4500 NO <sub>3</sub> -B
06	Fluoride	APHA 24 <sup>th</sup> EDN, METHOD 4500F-B
07	Iron	APHA 24 <sup>th</sup> EDN, METHOD 3500 Fe-B

**Reviewed By**

*Brotte*

**(Bacteriologist)**

**Authorised By**

*Yash*

**(TM/Chemist)**

\*\*\*\*\*End of Report\*\*\*\*\*



*A. S. N.*  
**Manager**  
Mount Camet Public School  
GOREGAON

*Yash*  
**Principal**  
Mount Camet Public School  
GOREGAON